

ITEM LIST

- 1 quantity aluminium or stainless steel service pillar, finished in slate grey to RAL 7015 and including:
* Long life hinges
* Two tri-headed key wedge locks 8mm
* Backboard from 18mm thick treated exterior grade plywood
* Detachable root section HDG and finished in bitumen enriched paint
* High quality UV resistant paint to a minimum thickness of 60 microns
* Cabinet, including door seal to IP 56
* Backboard can be removed for wiring
- 1 quantity glass reinforced plastic distribution enclosure with clear plastic door. To accommodate 24 modules (2 x 12).
- 1 quantity 63A isolator / switch disconnecter with red lockable actuator. 2 pole minimum with integral earth terminal.
- 1 quantity brass gland plate to accommodate a 6 gland cable arrangement.
- 1 quantity brass gland plate to accommodate a 1 gland cable arrangement.
- Threaded plastic blanking plugs for enclosure base.
- 10mm brass earth stud positioned as shown with metal label indicating earth terminal.
- 5 way earth block with plastic cover.
- 25mm polypropylene conduit installed with appropriate non conductive glands to ensure correct IP rating maintain.
- Series 6 service cut-out.
- 1 quantity varnished exterior grade 18mm plywood backing board, non hygroscopic.
- Insulated 2-pole bus bar to supply MCB's.
- 16mm2 double insulated tails (Live and Neutral)
- Nylon compression glands.
- Earth label to BS 7671 - Safety electrical connection - do not remove.

ITEM LIST

- 16mm2 Earth cable
- 16mm2 Earth cable - length 400mm
- Order Package Configuration Sheet (OPCS)
- TS35 Rail mounted terminals
- Separators
- End Stops.
- Adjustable depth TS35 rail.
- Plastic Locknuts

This drawing was generated on computer and must not be manually updated

TYPICAL ITEM LIST FOR LAYOUT TRAFFIC EQUIPMENT TERMINATION PILLAR (TEDP)



Note:
The NDX series of drawings represents non site specific installations of standard equipment and site layouts.

ORIGINAL DRAWING SIZE: 297 x 420	DRN	S.D.	CHKD	S.M.	SCALE
ALL DIMENSIONS ARE IN MM	DATE	29.02.08	DATE	29.02.08	N.T.S.
TOLERANCE +- 1 UNLESS OTHERWISE STATED	DRG. NO.	NDX1011-08ii		SHT. NO.	2 of 4
THIRD ANGLE PROJECTION DO NOT SCALE	ISSUE	AMENDMENTS	APPD/DATE		
	1	FIRST ISSUE	SM 10/03/08		
	A	REDRAWN	BD 13/10/09		