



Typical Method of Marking Cables

**NOTES**

1. All cables shall be clearly and unambiguously marked to show details of cable routes and destinations.
2. Cable ident legend should be agreed with the Engineer prior to fitting.
3. Maximum of 12 letters and/or numerals may be fitted to any cable.
4. Critchley or multicomp 'straight cut oval' type markers, Hellerman 'Ovalgrip' or similar should be used.
5. Reference should be made to the Scottish Series clause 1507.14 for usage.



Note:  
The NDX series of drawings represents non site specific installations of standard equipment and site layouts.

This drawing was generated on computer and must not be manually updated

TITLE	TYPICAL CABLE IDENTIFICATION LABELS
-------	-------------------------------------

ORIGINAL DRAWING SIZE: 297 x 420	DRN	C.S.G.	CHKD	B.D.	SCALE
ALL DIMENSIONS ARE IN MM	DATE	25.09.01	DATE	29.09.01	N.T.S.
TOLERANCE +- 1 UNLESS OTHERWISE STATED	DRG. NO.	NDX1061-00dt		SHT. NO.	3 of 6
THIRD ANGLE PROJECTION DO NOT SCALE	ISSUE	AMENDMENTS		APPD/DATE	
	B	REDRAWN			BD 13/10/09
	A	FOR INFORMATION			BD 04/02/02
	C	UPDATED SEE REV. SHT.			BD 30/1/09