


NOTES
 BEFORE CAPPING, THE CABLE SHALL BE CUT SQUARE AND THE LENGTH OF CABLE TO BE CAPPED SHALL BE THOROUGHLY CLEANED USING A DRY CLEAN CLOTH OR CLEANING FLUID APPROVED BY THE CABLE MANUFACTURER FOR THE PURPOSE.



This drawing was generated on computer and must not be manually updated

TITLE METHOD OF SEALING UNUSED CABLE ENDS

A	FOR CONSTRUCTION	BD 09/02/03
2	MODIFIED AS PER REV SHT	BD 07/01/02
1	FIRST ISSUE	BD 07.12.2001
AMENDMENTS		
DRN	C.S.G.	CHKD B.D.
DATE	01.12.01	DATE
DRG. NO.	NDX1061-00dt	
SHT. NO.	2 of 6	

ORIGINAL DRAWING SIZE: 297 x 420
 ALL DIMENSIONS ARE IN MM
 TOLERANCE ± 1 UNLESS OTHERWISE STATED
 THIRD ANGLE PROJECTION DO NOT SCALE



SCOTTISH EXECUTIVE
 Traffic Controller Unit,
 EDINBURGH, EH8 8QQ
 NADICS
 www.nadics.org.uk